

## SITEMATE POWER SYSTEMS LTD

Supplier Declaration of Conformity

| Sdoc Identification. | <b>SMWB (</b> Wall mounted distribution enclosure) | Issued | 28/01/2022 |
|----------------------|--|--------|------------|
|                      |  |        |            |

| Supplier Details.          |                                  |
|----------------------------|----------------------------------|
| Sitemate Power Systems Ltd | Company Number: 7009453          |
| 58 Rangi Road, Takanini    | Phone: +64 9 282 2366            |
| Auckland                   | Email: sales@sitematepower.co.nz |
| New Zealand                | Web: www.sitematepower.co.nz     |

## Product Details.

Wall mounted distribution enclosure Brand: Sitemate Models: SMWB, SM41, SM51, SM52

| Variants to Parent Product. |  |  |
|-----------------------------|--|--|
| Ratings                     | 230-415Vac 50 Hz 10A, 15A, 16A, 20A, 32A, 40A, 63A Built to Client's     |  |
|                             | specifications   |  |
| IP Rating                   | IP44, 56, 66 As per Clients specification                                |  |
| Circuit Protection          | Eaton Main switch, RCCB, RCBO, MCB as per Clients electrical request     |  |
| Socket outlets              | Scame Ceeform configuration sockets, Drylock or sockets specified by the |  |
|                             | client.  |  |

| Standards that relate to the product and its components, current as at date of manufacture. |   |  |
|---|---|--|
| AS/NZS 3100:2017  | Approval and test specification - General requirements for electrical equipment                         |  |
| AS/NZS 3112   | Approval and Test Specification – Plugs and sockets   |  |
| AS/NZS 3123   | Approval and Test Specification – Plugs, socket outlets and couplers for General Industrial Application |  |
| AS 60529  | Degrees of Protection Provided by Enclosures (IP Code)  |  |
| IEC 60309.1   | Plugs, socket-outlets and couplers for industrial purposes  |  |
| AS/NZS 60898.1  | Circuit Breakers for A.C. Operation   |  |
| AS/NZS 61008  | Residual Current Operated Circuit Breakers without Integral<br>Overcurrent Protection                   |  |
| AS/NZS 61009  | Residual Current Operated Circuit Breakers with Integral Overcurrent<br>Protection                      |  |



## SITEMATE POWER SYSTEMS LTD

Supplier Declaration of Conformity

Names and Addresses of Evaluation/Testing/Certification organisation or body used.

Sitemate Test and record all products to ensure compliance with the above standards. All records are retained by Sitemate for this assembly.

| Declaration   |                                    |  |  |  |
|---|------------------------------------|--|--|--|
| I hereby declare the above specified fittings or electrical appliances comply with Regulation 83 of the Electrical (Safety) Regulations 2010. |                                    |  |  |  |
| Signed for on behalf of:  | Sitemate Power Systems Ltd         |  |  |  |
| Jescon  | Issuer Identification:             |  |  |  |
| Dean Lipscombe  | Date 24 <sup>th</sup> January 2022 |  |  |  |
| Sitemate Product Development Manager  |                                    |  |  |  |